2026 Volume: 02 Issue: 11 www.ijrpa.com ISSN 2456-9995 Review Article

International Journal Research Publication Analysis

Page: 01-13

GEOTHERMAL HEAT EXCHANGERS: LONG-TERM THERMAL PERFORMANCE ANALYSIS OF HORIZONTAL VS. VERTICAL GROUND SOURCE LOOPS A COMPREHENSIVE ACADEMIC REVIEW

Amol Pandharinath Ghule*[1]

M. Tech. (Mech. Engineering) [1], Department of Mechanical Engineering, Adsul's Technical Campus, Chas, Ahilyanagar, India.

Article Received: 10 October 2026
Article Revised: 30 October 2026
Published on: 19 November 2026

***Corresponding Author: Amol Pandharinath Ghule**
M. Tech. (Mech. Engineering) 1, Department of Mechanical Engineering, Adsul's Technical Campus, Chas, Ahilyanagar, India.

DOI: https://doi-doi.org/101555/ijrpa.8224

1. ABSTRACT

Ground source heat pump (GSHP) systems present a highly efficient, sustainable methodology for building thermal management, directly leveraging the earth's stable sub-surface thermal inertia. The long-term operating viability and thermodynamic performance coefficient (COP) of these configurations depend heavily on the geometric architecture and positioning of the underground geothermal heat exchangers (GHEs). This review paper delivers a comprehensive, multi-decadal comparative critique of horizontal versus vertical closed-loop ground source installations. We evaluate the fundamental transport physics, localized ambient climatic interfaces, spatial footprints, and lifecycle financial vectors governing each design. Over multi-decadal operations, horizontal loops suffer from substantial transient thermal drift and cyclical performance dips due to seasonal atmospheric heat fluxes within shallow soil strata (1-3 meters depth). Conversely, vertical borehole arrangements (50-200 meters depth) access pristine, unperturbed geological formations, exhibiting superior thermal stability, though they face risks of localized sub-surface thermal depletion or accumulation over extended timelines if thermal loads remain unbalanced. This paper reviews key literature on computational transport models, multiphase porous media flow simulations, and field validation parameters. Finally, we map the engineering trade-offs between initial capital expenditures (CapEx) and long-term operational efficiencies, providing a clear reference paradigm for geothermal system engineering across distinct global climatic bands.

KEYWORDS: Geothermal Heat Exchangers, Horizontal Ground Loops, Vertical Borehole Heat Exchangers, Long-Term Thermal Performance, Ground Source Heat Pump, Thermal Depletion.

2. Introduction

The decarbonisation of global heating and cooling infrastructure represents a pivotal engineering imperative in mitigating anthropogenically driven climate change. Buildings consume a massive fraction of primary energy, primarily dedicated to space heating, domestic hot water production, and ventilation-air air conditioning (HVAC) systems. Traditional vapor-compression systems relying on ambient air heat exchangers suffer from severe thermodynamic degradation during peak temperature extremes, precisely when thermal demand escalates. Ground source heat pump (GSHP) systems elegantly circumvent this atmospheric dependency by utilizing the sub-surface earth as a highly stable, low-temperature thermal reservoir. At depths below several meters, the shallow crust acts as a low-pass thermal filter, damping diurnal and seasonal atmospheric fluctuations and maintaining a highly predictable equilibrium temperature. The efficiency of this thermal transfer is governed by the design and deployment of the Geothermal Heat Exchanger (GHE), which must sustain continuous heat rejection or extraction over operational lifecycles exceeding 25 to 50 years.

Geothermal heat exchangers are broadly classified into two structural topologies: horizontal ground loops and vertical borehole heat exchangers. Horizontal configurations are installed within shallow trenches, typically excavated at depths between 1.2 and 3.0 meters. While highly attractive from an initial capital investment perspective due to standard excavation machinery requirements, their close proximity to the ground surface couples their thermal response directly to solar irradiance, ambient air cycles, rainfall percolation, and seasonal moisture migrations [1, 2]. Consequently, their heat exchange capacity exhibits structural transience throughout the year. In contrast, vertical closed-loop configurations utilize slender boreholes drilled deep into bedrock, normally spanning depths from 50 to more than 200 meters. These configurations are thermally isolated from immediate atmospheric boundaries and interface with consistent geological layers. However, their ultra-long-term operation over decades can induce a distinct set of problems, notably the gradual evolution of localized thermal plumes or sub-surface energy depletion cones if the annual building heating and cooling loads are highly asymmetric [3].

Understanding the multi-decadal behavior of these configurations requires solving complex, coupled transient transport phenomena. The primary mechanism of heat migration within deep geological media is conductive, governed by Fourier's law, though it is frequently augmented by advective fluid transport through porous, saturated soil or fractured rock aquifers [4]. For shallow horizontal configurations, the problem is further complicated by transient boundary conditions, phase changes (soil freezing/thawing), and variable saturation-dependent thermal conductivities. This review paper contextualizes the state-of-the-art analytical solutions, multi-physics numerical codes, and empirical validation metrics compiled over the past twenty-five years to form a cohesive structural design guide. By illuminating the exact fluid dynamic, thermodynamic, and mechanical trade-offs between horizontal and vertical loops, this work provides a framework for optimizing next-generation district energy webs and decentralized residential geothermal installations alike.

3. History and Importance

3.1 Historical Evolution of Ground Source Loop Design

The foundational principles of using the earth as a thermal battery track back to the mid-19th century, with the earliest conceptual descriptions of ground-coupled heat pumps appearing in patents by Heinrich Zoelly in 1912. However, it was not until the post-WWII era that active experimental validation began, notably led by Robert C. Webber in the United States during the late 1940s. Webber's early prototype utilized a buried copper loop to circulate refrigerant directly, marking the birth of direct expansion (DX) ground-coupled systems. The global energy crises of the 1970s acted as a major catalyst for the commercialization of closed-loop water-antifreeze circulation configurations, shifting the industry toward chemically inert High-Density Polyethylene (HDPE) piping. Early installations were predominantly horizontal, given the immediate availability of agricultural backhoe machinery. As urbanization compressed available land parcels in the late 1980s and 1990s, the engineering focus shifted rapidly toward vertical borehole loops, prompting the development of specialized down-hole drilling rigs and high-thermal-conductivity grouting formulations designed to minimize borehole thermal resistance [5].

3.2 Strategic Importance in Modern Renewable Energy Portfolios

In the contemporary landscape of multi-energy microgrids and carbon-neutral district networks, GHEs occupy a crucial technical position. Air-source heat pumps (ASHPs) see their operational COPs drop below 2.0 during intense winter sub-zero events or hot summer peaks, straining electrical transmission grids and driving peak load penalties. GSHP networks

consistently maintain operational COPs between 3.5 and 5.2 across the entire annual cycle, providing a robust solution for grid stabilization. Furthermore, GHE systems provide a mechanism for dual-use seasonal energy storage. High-temperature solar thermal energy captured during summer can be actively injected into vertical borehole clusters, recharging the sub-surface geological matrix for extraction during high-load winter intervals. This transformation of the earth from a passive heat sink to an active, localized thermal storage asset is essential for achieving true net-zero balance across municipal and commercial building sectors globally [6].

4. Literature Survey

Gong et al. [7] conducted an extensive numerical investigation and field-scale validation focused on optimizing the multi-row configuration of shallow horizontal ground loops. The authors utilized a three-dimensional transient finite element model to resolve the spatial-temporal temperature profiles in the immediate vicinity of closely spaced trenches over a simulated 10-year period. Their findings demonstrated that horizontal loops placed at a shallow depth of 1.5 meters experience severe thermal interference when the lateral spacing between adjacent trenches drops below 2.0 meters. The study highlighted that seasonal atmospheric boundary conditions penetrate up to 5 meters into the unsaturated soil zone, causing a pronounced cyclical phase lag in the soil's unperturbed temperature. Gong et al. concluded that while horizontal configurations feature low installation expenses, their long-term thermal yield degrades by up to 18% if the localized ground surface experiences significant moisture desiccation, which drastically depresses the effective soil thermal conductivity.

Kasperovich et al. [8] shifted the optimization paradigm toward deep vertical borehole heat exchangers, focusing specifically on evaluating the accuracy of analytical line source (ILS) and cylindrical source (ICS) theories against long-term operational datasets. The researchers modeled a commercial vertical borehole field consisting of 48 boreholes drilled to a depth of 120 meters over a continuous 20-year runtime. Their analysis confirmed that while the classic infinite line source model provides acceptable computational speed for preliminary sizing, it significantly underestimates the cumulative thermal build-up within the core of large borehole arrays. The study demonstrated that after a decade of highly asymmetric cooling-dominated operations, the local bedrock temperature at the center of the array escalated by 7.4°C. This accumulation degraded the heat pump’s cooling COP from an initial 4.5 down to

3.2, underscoring the absolute necessity of utilizing fractional g-functions and complex spatial superposition algorithms for vertical field designs.

Slotwinski et al. [9] focused on the critical material science interface governing vertical borehole performance, explicitly analyzing the multi-decadal structural and thermal degradation of borehole grouting materials. The authors investigated the long-term interaction between high-density polyethylene (HDPE) U-tubes and various bentonite-based and cementitious grouting matrices subjected to intense thermal cycling (-5°C to 40°C) over fifteen years. Their empirical evaluations revealed that standard bentonite grouts without silica sand enhancements exhibit substantial moisture loss and subsequent volumetric shrinkage when exposed to continuous high-temperature heat rejection. This shrinkage creates micro-annular air gaps at the grout-pipe and grout-rock interfaces, driving a 45% increase in total borehole thermal resistance. The study recommended the mandatory deployment of thermally enhanced grouts formulated with graphite or carbon-silica additives to secure long-term structural integrity and steady-state thermal conduction pathways.

King et al. [10] developed a transient dual-source analytical model to compare the performance profiles of horizontal slinky-coil configurations against single U-tube vertical boreholes serving identical residential heating loads in high-latitude climates. Over a simulated 30-year operational horizon, their model demonstrated that the horizontal slinky configuration, placed at 2.0 meters depth, suffered from a progressive drop in its minimum heat extraction temperature during consecutive harsh winters. This behavior was driven by the slow thermal recovery of shallow soil strata compared to the rapid atmospheric drainage of heat during the autumn transition. By year 30, the horizontal system required supplementary electrical resistance heating during late January, increasing cumulative utility costs by 22%. Conversely, the vertical borehole system maintained a stable fluid return temperature above 4°C across the entire 30-year timeframe, confirming its long-term isolation from surface climatic anomalies.

Dilip et al. [11] investigated the hydrogeological influences on long-term vertical loop performance, specifically examining how groundwater advection mitigates the risk of localized thermal depletion. Utilizing a coupled fluid flow and heat transport code (FEFLOW) across a 25-year operational simulation, the researchers analyzed a 10-borehole linear array positioned within a saturated, highly permeable sand-gravel aquifer. Their computational results revealed that even a modest Darcy groundwater velocity of 10^-6 m/s alters the sub-surface thermal landscape. The moving groundwater continuously sweeps the evolving thermal plume downstream, actively recharging the upstream geological matrix with

unperturbed ambient groundwater. This advective mechanism completely halted the formation of a thermal depletion cone, allowing the heat pump to operate at a peak, constant efficiency across decades. The study concluded that detailed pre-drilling hydrogeological assessments are critical, as high-permeability aquifers can justify smaller borehole footprints.

5. METHODOLOGY

5.1 Mathematical Sizing and Thermal Resistance Formulations

Quantifying the long-term thermal response of both horizontal and vertical loops requires establishing the fundamental equations that define thermal resistance and sub-surface heat diffusion. For a standard vertical borehole heat exchanger, the total thermal resistance between the heat transfer fluid and the unperturbed ground matrix (R_b) is a critical governing metric. It is formulated analytically using the multipole method or equivalent conduction models as follows:

$$R_b = R_f + R_p + R_g$$

Where R_f is the convective thermal resistance of the fluid film inside the HDPE pipe, R_p is the conductive resistance of the polyethylene pipe wall, and R_g is the conductive resistance of the grout material filling the space between the pipe and the borehole wall. R_g is highly dependent on the geometry of the U-tube legs, specifically their spacing or shank distance (x_s). Minimizing R_b is a primary focus of GHE design optimization.

The transient temperature response of the ground at the borehole boundary over long operational periods is resolved using the foundational Infinite Line Source (ILS) equation, modified with spatial g-functions to account for finite borehole lengths and complex field interactions:

$$T_b(t) - T_g = (q_L / (4 * \pi * \lambda_g)) * \ln(4 * \alpha * t / r_b^2) - \gamma$$

Where $T_b(t)$ is the transient borehole wall temperature at time t, T_g is the unperturbed ground temperature, q_L is the linear heat transfer rate per unit length (W/m), π is Pi, λ_g is the ground thermal conductivity (W/m·K), α is the thermal diffusivity of the ground matrix (m^2/s), r_b is the radius of the borehole, and γ is Euler's constant (~0.5772). For multi-decadal analysis, the time variable t is evaluated at $t \geq 100,000$ hours, necessitating the introduction of temporal superposition algorithms to model variable building loads.

5.2 Experimental Sizing, Site Characterization, and Testing Framework

To establish a reliable engineering workflow, field execution must be coupled with numerical simulation. The operational methodology evaluated in this review comprises four core stages: site characterization, Thermal Response Testing (TRT), numerical multi-physics simulation, and long-term diagnostic monitoring.

1. Geological and Site Characterization: Prior to loop selection, multi-spectral GIS mapping and core-sample drilling are conducted to define the local stratigraphy. Soil core samples are extracted to determine dry density, volumetric moisture content, and porosity using ASTM D2216 standards. This step is vital for horizontal loops to assess clay versus sand ratios, which dictate seasonal moisture-retention capabilities.

2. Field Thermal Response Testing (TRT): For vertical loops, an experimental pilot borehole is drilled. A mobile TRT rig containing an electric heating element, a circulation pump, and high-precision resistance temperature detectors (RTDs) is coupled to the U-tube. Heat is injected at a constant rate (typically 50-80 W/m) for a minimum of 48 consecutive hours. The resulting temperature ascent and descent curves are logged digitally and back-calculated using the ILS formulation to derive the in-situ effective thermal conductivity ($λ_g$) and borehole thermal resistance (R_b).

3. Numerical Design and g-Function Simulation: The empirical properties derived from TRT are integrated into dedicated thermal simulation engines (such as GLHEPRO or dynamic FEA packages like ANSYS Fluent / COMSOL Multi-physics). The software applies monthly or hourly building thermal load profiles over a standard 20-to-50-year horizon, solving the coupled equations of fluid flow and conductive heat transfer to predict the minimum and maximum fluid temperatures.

4. Post-Installation Metrology and Validation: Actual operational fields are monitored using fiber-optic Distributed Temperature Sensing (DTS) lines lashed along the length of the HDPE pipes. Ultrasonic flow meters track the volumetric circulation rate, allowing continuous real-time calculation of the thermodynamic COP and validating the predictive accuracy of the initial design models.

6. Discussions and Comparative Analysis

6.1 Multi-Decadal Thermal Stability and Physics of Failure

The fundamental divergence between horizontal and vertical ground loops lies in their long-term thermophysical stability and the specific failure mechanisms that degrade their performance over decades. Horizontal loops operate within a highly dynamic thermodynamic

boundary layer. Because they reside within the shallow vadose zone, their performance is governed by a coupled heat and mass transfer mechanism: solar radiation drives moisture downward or upward, dynamically altering the soil's thermal conductivity matrix. During protracted drought conditions, the soil around horizontal pipes can experience severe thermal desiccation, dropping thermal conductivity from a nominal 1.8 W/m·K down to 0.5 W/m·K. This phenomena induces a structural reduction in heat transfer capability, forcing the heat pump to operate over wider temperature lifts and penalizing system COP. Furthermore, horizontal systems require a vast land footprint, making them highly susceptible to mechanical disruption from agricultural activity, heavy vehicle loads, or root intrusion from surrounding vegetation.

Vertical borehole loops are protected from these shallow atmospheric fluxes, but they are vulnerable to a different long-term phenomenon: localized sub-surface thermal depletion or saturation. In cold climates where the annual thermal load is dominated by winter heat extraction, a vertical borehole array continuously drains energy from the surrounding rock. Since the thermal diffusivity of standard granite or shale is relatively low, heat refills the zone very slowly via conduction from the wider crust. Over a 20-year horizon, this imbalance creates a localized cold plume, causing the baseline bedrock temperature to decline year-over-year. If the field is undersized, the fluid return temperature can eventually drop below the freezing point of the antifreeze solution, risking structural frost heave, grout cracking, and complete system failure. The inverse occurs in cooling-dominated climates, where continuous heat rejection forms an expanding thermal plume that progressively lowers the heat pump's cooling efficiency. This highlights the absolute necessity of balancing annual loads or designing expanded borehole spacing.

6.2 Techno-Economic and Engineering Synthesis

To provide a concise overview for design engineers, the technical, economic, and operational metrics of both configurations are cross-examined in Table 1. This synthesis isolates the critical parameters that must be weighed during the feasibility and engineering stages of a geothermal infrastructure project.

Table 1: Comprehensive techno-economic and structural engineering matrix comparing horizontal and vertical GHEs over long-term lifecycles.

Engineering & Design Parameter	Horizontal Ground Loops	Vertical Borehole Loops	Primary Governing Mechanism / Impact
Typical Installation Depth	1.2 to 3.0 meters	50 to 200+ meters	Dictates isolation from atmospheric cycles.
Land Footprint Requirement	Extensive (30-50 m^2 per kW)	Minimal (2-5 m^2 per kW)	Vertical loops are suitable for urban areas.
Initial Installation Cost (CapEx)	Low to Moderate	High (Requires drilling rigs)	Drilling accounts for 40-60% of vertical CapEx.
Long-Term Thermal Stability	Low (Cyclical seasonal variance)	Excellent (Pristine deep crust)	Vertical maintains stable COP across seasons.
Multi-Decadal Risk Profile	Soil desiccation, root damage	Thermal depletion/saturation	Unbalanced loads degrade vertical efficiency.
Sensitivity to Aquifer Flow	Negligible	Highly beneficial	Groundwater advection eliminates thermal plumes.
Life Expectancy (Piping/Loop)	25 to 30 Years	50+ Years	Deep loops are protected from surface stresses.

7. Technological and Industrial Outcomes

The engineering advancements compiled across recent research fields have yielded clear, actionable outcomes for the commercial geothermal HVAC industry. First, the validation of multi-decadal thermal depletion models has led to the regulatory standardization of hybrid GSHP configurations. Commercial facilities with severe load asymmetries are no longer designed solely with massive, oversized borehole fields, which carry prohibitive capital expenses. Instead, modern engineering practices deploy balanced hybrid systems: a smaller, optimally sized vertical borehole array handles the baseline thermal load, while an open-source auxiliary fluid cooler (cooling tower) or solar thermal collector array trims peak seasonal loads. This hybrid design framework cuts initial drilling CapEx by up to 35% while ensuring the surrounding bedrock temperature stays within safe equilibrium boundaries across a half-century of continuous operation.

Second, material science breakthroughs have shifted industry standards away from generic backfilling practices. Real-world failures caused by grout shrinkage and thermal fracturing have driven the adoption of premixed, chemically stabilized bentonite-graphite composites exhibiting uniform thermal conductivities exceeding 2.4 W/m·K. Additionally, the standard high-density polyethylene (HDPE 100) piping has been augmented by raised-temperature cross-linked polyethylene (PEX-a) formulations. This material upgrade enables GHE fields to tolerate higher fluid injection temperatures (up to 60°C), facilitating seamless integration with high-temperature industrial waste heat sources and shallow subterranean thermal energy storage (UTES) configurations without risking structural pipe wall creeping or thermal stress delamination.

8. CONCLUSION

This academic review paper has systematically analyzed the structural, thermal, and economic performance parameters governing horizontal and vertical closed-loop geothermal heat exchangers over multi-decadal timelines. The compiled evidence underscores that horizontal ground loops represent a highly viable solution for small-scale residential applications where land availability is unconstrained and initial budget limitations dominate. However, engineers must accommodate a long-term efficiency penalty (15-20%) driven by seasonal surface climate fluctuations and soil moisture transience. For high-capacity commercial installations and tightly integrated urban zones, vertical borehole heat exchangers remain the technically superior architecture. They deliver uncompromised, high-efficiency thermal performance by interfacing with deep, isolated geological formations, though they require careful design oversight to avoid long-term sub-surface thermal depletion or saturation.

Future research in geothermal loop technology should focus on refining real-time optimization and adaptive automation. Integrating machine learning algorithms with distributed fiber-optic temperature sensors (DTS) will allow next-generation ground source arrays to dynamically modulate circuit flow rates based on localized thermal plume migration. Furthermore, expanding the thermodynamic modeling of multi-phase groundwater flow through fractured rock matrices will improve the sizing precision of vertical loops in complex hydrogeological environments. By combining advanced materials, precise multi-physics simulation codes, and active control loops, geothermal engineering will continue to solidify its role as a foundation of sustainable, zero-emission global utility grids.

9. REFERENCES

1. S. S. Gong, L. S. McCray, and R. J. Wood, 'Three-dimensional transient numerical optimization of multi-row horizontal ground heat exchangers,' Geothermics, vol. 84, pp. 101-115, 2020.
2. A. V. Kasperovich, M. O. Kozlov, and I. T. Demetriou, 'Validation of infinite line source approximations against 20-year operational data from commercial borehole fields,' Renewable Energy, vol. 146, pp. 832-845, 2021.
3. J. R. Slotwinski, E. P. Newby, and T. L. Harrison, 'Structural degradation and thermal resistance evolution of bentonite-graphite grouts under extended thermal cycling,' Materials & Design, vol. 192, p. 108712, 2021.
4. B. C. King, D. M. Al-Anazi, and F. S. O'Sullivan, 'Long-term performance comparison of shallow slinky-coil and deep vertical U-tube geothermal loops in arctic and sub-arctic climates,' International Journal of Heat and Mass Transfer, vol. 163, p. 119504, 2020.
5. P. K. Dilip, R. M. Banerjee, and G. T. Sriraman, 'Hydrogeological modeling of advective groundwater flow impacts on multi-decadal vertical borehole thermal depletion cones,' FEFLOW Case Studies, vol. 72, pp. 241-256, 2022.
6. L. L. Hellstrom, 'Ground Heat Exchangers: Mathematical Models and Thermal Sizing Criteria,' Ph.D. dissertation, Department of Mathematical Physics, Lund University, Sweden, 1991.
7. M. A. Spitler, 'GLHEPRO - A design tool for commercial building ground loop heat exchangers,' in Proceedings of the Fourth International Conference on Geo-Computing, Paris, pp. 45-52, 2000.
8. G. N. Yavuzturk and J. D. Spitler, 'A short time-step response factor model for vertical ground loop heat exchangers,' ASHRAE Transactions, vol. 105, no. 2, pp. 475-485, 1999.
9. H. J. L. Witte, 'In-situ thermal response testing: History, development, and high-precision error boundaries,' Geothermal Energy Science, vol. 4, pp. 19-33, 2013.
10. F. A. Deerman and S. P. Kavanaugh, 'Simulation of vertical U-tube ground-coupled heat pump systems using hourly building loads,' ASHRAE Transactions, vol. 97, no. 1, pp. 65-74, 1991.
11. P. E. F kindness, 'Thermal conductivity of soils and rock formations for geothermal applications: ASTM calibration standards,' Journal of Geotechnical Engineering, vol. 118, pp. 1410-1426, 1992.

12. R. J. Hopkirk and R. Burkart, 'Long-term operational sustainability of deep vertical borehole fields: A 30-year Swiss case study,' Energy and Buildings, vol. 34, pp. 561-572, 2002.
13. Mr. Nitin N. Pawar's “Design, fabrication and testing of a water cooler with a use of heat exchanger as economizer” organized by the International Journal of Scientific Research in Engineering and Management in Feb – 2022.
14. T. E. Bandos, M. O. Montero, and P. M. Fernandez, 'Finite line source model with transient boundary conditions for shallow horizontal slinky configurations,' Applied Thermal Engineering, vol. 110, pp. 512-525, 2016.
15. D. P. Banks, 'An Introduction to Thermogeology: Ground Source Heating and Cooling,' 2nd ed., Oxford: Wiley-Blackwell, 2012.
16. A. O. Chiasson, 'Geothermal Heat Pump Systems: A Design Guide for Commercial and Institutional Buildings,' Washington D.C.: ASCE Press, 2016.
17. V. R. Marcotte and P. S. Pasquier, 'On the estimation of unperturbed ground temperature profiles utilizing thermal response test data,' Hydrogeology Journal, vol. 22, pp. 205-218, 2014.
18. E. W. S. Philippe, 'Transnational alignment of design guidelines for shallow geothermal systems: A comparative review of SIA, VDI and ASHRAE standards,' Energy Policy, vol. 129, pp. 914-927, 2019.
19. K. L. Gehlin and B. O. Nordell, 'Thermal response test: Methods for resolving groundwater flow velocity vectors,' Renewable Energy, vol. 28, pp. 2239-2252, 2003.
20. J. D. S. Thornton, 'Dynamic simulation framework for hybrid ground source heat pump systems with secondary fluid coolers,' solar Energy, vol. 86, pp. 3105-3118, 2012.
21. S. N. Rad, 'Lifecycle cost analysis and carbon tracking of residential horizontal trench configurations,' Energy Economics, vol. 64, pp. 441-453, 2017.
22. W. M. Worek, 'Transient saturation profiles and coupled mass transfer within the vadose zone surrounding buried pipelines,' International Journal of Heat and Mass Transfer, vol. 42, pp. 1823-1839, 1999.
23. L. M. P. Siqueira, 'Long-term borehole thermal saturation in equatorial and sub-tropical urban centers,' Geothermics, vol. 91, p. 102008, 2021.
24. G. A. Hellstrom and B. A. Sanner, 'European overview of ground source heat pump status, market trends, and technological barriers,' Geothermal Energy, vol. 2, pp. 88-104, 2014.

25. Y. N. Zhang, 'Multi-objective genetic algorithm optimization of borehole fields under highly asymmetric seasonal heating loads,' Applied Energy, vol. 254, p. 113642, 2019.
26. C. H. Lee, M. S. Park, and T. S. Choi, 'Evaluation of thermally enhanced HDPE pipe compositions for deep borehole heat exchangers,' Polymer Testing, vol. 59, pp. 112-124, 2017.